

# **Design, Construction, Operation, Maintenance, and Inspection of Terminal and Tank Facilities**

API STANDARD 2610  
FOURTH EDITION, MARCH 2026



American  
Petroleum  
Institute

## Special Notes

API publications necessarily address problems of a general nature. With respect to particular circumstances, local, state, and federal laws and regulations should be reviewed. The use of API publications is voluntary. In some cases, third parties or authorities having jurisdiction may choose to incorporate API standards by reference and may mandate compliance.

Neither API nor any of API's employees, subcontractors, consultants, committees, or other assignees make any warranty or representation, either express or implied, with respect to the accuracy, completeness, or usefulness of the information contained herein, or assume any liability or responsibility for any use, or the results of such use, of any information or process disclosed in this publication. Neither API nor any of API's employees, subcontractors, consultants, or other assignees represent that use of this publication would not infringe upon privately owned rights.

API publications may be used by anyone desiring to do so. Every effort has been made by the Institute to ensure the accuracy and reliability of the data contained in them; however, the Institute makes no representation, warranty, or guarantee in connection with this publication and hereby expressly disclaims any liability or responsibility for loss or damage resulting from its use or for the violation of any authorities having jurisdiction with which this publication may conflict.

API publications are published to facilitate the broad availability of proven, sound engineering and operating practices. These publications are not intended to obviate the need for applying sound engineering judgment regarding when and where these publications should be used. The formulation and publication of API publications is not intended in any way to inhibit anyone from using any other practices.

Any manufacturer marking equipment or materials in conformance with the marking requirements of an API standard is solely responsible for complying with all the applicable requirements of that standard. API does not represent, warrant, or guarantee that such products do in fact conform to the applicable API standard.

All rights reserved. No part of this work may be reproduced, translated, stored in a retrieval system, or transmitted by any means, electronic, mechanical, photocopying, recording, or otherwise, without prior written permission from the publisher. Contact the Publisher, API Publishing Services, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001-5571.

## Foreword

Nothing contained in any API publication is to be construed as granting any right, by implication or otherwise, for the manufacture, sale, or use of any method, apparatus, or product covered by letters patent. Neither should anything contained in the publication be construed as insuring anyone against liability for infringement of letters patent.

The verbal forms used to express the provisions in this document are as follows.

Shall: As used in a standard, “shall” denotes a minimum requirement to conform to the standard.

Should: As used in a standard, “should” denotes a recommendation or that which is advised but not required to conform to the standard.

May: As used in a standard, “may” denotes a course of action permissible within the limits of a standard.

Can: As used in a standard, “can” denotes a statement of possibility or capability.

This document was produced under API standardization procedures that ensure appropriate notification and participation in the developmental process and is designated as an API standard. Questions concerning the interpretation of the content of this publication or comments and questions concerning the procedures under which this publication was developed should be directed in writing to the Director of Standards, American Petroleum Institute, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001. Requests for permission to reproduce or translate all or any part of the material published herein should also be addressed to the director.

Generally, API standards are reviewed and revised, reaffirmed, or withdrawn at least every five years. A one-time extension of up to two years may be added to this review cycle. Status of the publication can be ascertained from the API Standards Department, telephone (202) 682-8000. A catalog of API publications and materials is published annually by API, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001.

Suggested revisions are invited and should be submitted to the Standards Department, API, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001, [standards@api.org](mailto:standards@api.org).



# Contents

	Page
<b>1</b>	Scope and Purpose ..... 1
<b>1.1</b>	Overview ..... 1
<b>1.2</b>	Petroleum Terminals ..... 1
<b>1.3</b>	Pipeline Tankage Facilities ..... 1
<b>1.4</b>	Refinery Facilities ..... 1
<b>1.5</b>	Bulk Plants ..... 2
<b>1.6</b>	Lubricant Blending and Packaging Facilities ..... 2
<b>1.7</b>	Asphalt Plants ..... 2
<b>1.8</b>	Aviation Service Facilities ..... 2
<b>1.9</b>	Non-applicability and Retroactivity ..... 2
<b>1.10</b>	Governmental Requirements and Reviews ..... 3
<b>2</b>	Normative References ..... 3
<b>3</b>	Terms, Definitions, and Abbreviations ..... 12
<b>3.1</b>	Terms and Definitions ..... 12
<b>3.2</b>	Abbreviations ..... 14
<b>4</b>	Site Selection and Spacing Requirements ..... 15
<b>4.1</b>	Site Selection ..... 15
<b>4.2</b>	Spacing Requirements ..... 16
<b>5</b>	Pollution Prevention and Waste Management ..... 17
<b>5.1</b>	Applicability ..... 17
<b>5.2</b>	Waste Management Hierarchy ..... 18
<b>5.3</b>	Pollution Prevention ..... 19
<b>5.4</b>	Waste Management Practices ..... 21
<b>6</b>	Safe Operations of Terminals and Tanks ..... 23
<b>6.1</b>	General ..... 23
<b>6.2</b>	Hazard Identification ..... 23
<b>6.3</b>	Operating Procedures ..... 24
<b>6.4</b>	Safe Work Practices ..... 24
<b>6.5</b>	Emergency Response and Control Procedures ..... 24
<b>6.6</b>	Management of Change (MOC) ..... 25
<b>6.7</b>	Training ..... 25
<b>6.8</b>	Pre-start-up Safety Review (PSSR) ..... 26
<b>6.9</b>	Incident Investigation ..... 26
<b>6.10</b>	Contractor Safety ..... 26
<b>6.11</b>	Operations Safety Information ..... 27
<b>6.12</b>	Compliance Audits ..... 27
<b>6.13</b>	Employee Participation ..... 27
<b>6.14</b>	Trade Secrets ..... 27
<b>7</b>	Fire Prevention and Protection ..... 27
<b>7.1</b>	General ..... 27
<b>7.2</b>	Fire Prevention ..... 27
<b>7.3</b>	Fire-fighting Equipment ..... 29
<b>7.4</b>	Fire Extinguishment and Control ..... 29
<b>7.5</b>	Fire Protection Water Supplies ..... 31
<b>7.6</b>	Fire Emergency Plan ..... 31

## Contents

	Page
7.7	Exposure Protection ..... 32
7.8	Special Product Considerations..... 33
8	Tanks ..... 34
8.1	Aboveground Petroleum Storage Tanks ..... 34
8.2	Operations, Inspections, Maintenance, and Repair for Aboveground Tanks ..... 39
8.3	Fiberglass Reinforced Plastic (FRP) ASTs ..... 41
8.4	Underground Storage Tanks (USTs) and Piping ..... 41
8.5	UST Vapor Emissions ..... 42
9	Dikes and Berms ..... 42
9.1	Overview..... 42
9.2	Dikes ..... 42
9.3	Berms ..... 44
10	Pipe, Valves, Pumps, and Piping Systems ..... 44
10.1	General ..... 44
10.2	Material Compatibility ..... 45
10.3	Piping Systems ..... 45
10.4	Piping Components ..... 47
10.5	Pumps..... 49
10.6	Integrity Assurance of Existing Piping Systems ..... 50
10.7	Testing Following Construction ..... 51
11	Loading, Unloading, and Product Transfer Facilities ..... 51
11.1	Scope..... 51
11.2	General Design ..... 51
11.3	Truck Loading/Unloading ..... 52
11.4	Rail Tank Car Loading and Unloading ..... 56
11.5	Marine Loading/Unloading ..... 57
11.6	Aviation Loading/Unloading ..... 58
11.7	Vapor Control ..... 59
11.8	Oxygenate Blending ..... 61
11.9	Emergency Shutdown Systems and Procedures ..... 62
11.10	Product Testing ..... 62
11.11	Communication ..... 62
11.12	Measurements ..... 62
11.13	Valves, Lines, Loading Arms, and Hose Product Identification..... 62
11.14	Release Prevention System in Loading/Unloading Areas ..... 63
11.15	Maintenance/Testing ..... 63
11.16	Auxiliary Systems ..... 63
12	Corrosion Control..... 63
12.1	Scope..... 63
12.2	Protective Coatings..... 63
12.3	Internal Tank Lining..... 68
12.4	Cathodic Protection (CP) ..... 70
12.5	Vapor Corrosion Inhibitors (VCIs) ..... 73
13	Structures, Utilities, and Yard..... 74
13.1	Structures ..... 74

## Contents

	Page
<b>13.2</b> Utilities .....	75
<b>13.3</b> Yard.....	82
<b>14</b> Removals and Decommissioning of Facility .....	88
<b>14.1</b> General .....	88
<b>14.2</b> Site Control, Protection, and Preparations .....	89
<b>14.3</b> Execution .....	90
<b>14.4</b> Closeout and Cleanup .....	90
<b>14.5</b> Facility Lockout .....	91
<b>14.6</b> Signage and De-identification .....	91
Bibliography.....	92

## Figures

<b>1</b> Typical Electric Service and Distribution System Terminals and Bulk Plants.....	77
<b>2</b> Segregated Waste Stream in a Typical Terminal.....	80
<b>3</b> Tank Truck Loading Yard Layout Without Garage .....	84
<b>4</b> Tank Truck Loading Yard Layout with Garage .....	84
<b>5a</b> Yard Dimensions for Trucks (See Table Above) (SI).....	86
<b>5b</b> Yard Dimensions for Trucks (See Table Above) (USC).....	87

## Tables

<b>1</b> Example of ICC Codes .....	75
-------------------------------------	----



## Introduction

This standard was developed to guide the management of terminals and tanks in a manner that protects the environment and the safety of workers and the public. This standard is intended for petroleum terminal and tank facilities associated with marketing, refining, pipeline, and other similar facilities. This standard may be used as a resource and management guide by those responsible for such facilities and by those working on their behalf. This standard is a compilation of industry knowledge, information, and management practices for all relevant aspects of terminal and tank operations aggregated into an overview document comprising best practices. The standard references other API publications or similar industry guides and standards to provide greater detail and additional information. It is intended to be consistent with, but is not a substitute for, any applicable federal, state, and local regulations.

This standard presents requirements, recommendations, and options. Some provisions in this standard, as indicated by the use of the word shall, are mandatory and have to be followed to conform with this standard. Some provisions are recommended, as denoted by the word should, but are not mandatory. These provisions will need to be considered based on site-specific factors. Still other provisions are optional, as denoted by the word may. Typically, these will be given where a range of good options exists.

To foster greater awareness and assist the industry in addressing environmental, health, and safety concerns, API has undertaken the development of this single document aggregating the various standards, specifications, and recommended practices on the design, construction, operation, inspection, and maintenance of petroleum terminals and tanks.



# Design, Construction, Operation, Maintenance, and Inspection of Terminal and Tank Facilities

## 1 Scope and Purpose

### 1.1 Overview

This standard covers the design, construction, operation, inspection, and maintenance of petroleum terminal and tank facilities associated with marketing, refining, pipeline, and other similar activities as stipulated in [1.2](#) through [1.8](#). This standard covers site selection and spacing, pollution prevention and waste management, safe operation, fire prevention and protection, tanks, dikes and berms, mechanical systems, product transfer, corrosion protection, structures, utilities and yard, and removals and decommissioning.

The purpose of this standard is to consolidate a wide base of current industry experience, knowledge, information, and management practices into a cohesive standard comprising a range of best practices.

The values stated for this standard are in the International System of Units (SI) with U.S. Customary units provided in parentheses.

The petroleum industry is engaged in the manufacture, storage, transportation, blending, and distribution of crude oil and refined products. Individual terminal facilities and plants may perform one or more of these functions. These facilities represent diverse operations ranging from small distribution facilities (e.g. bulk plants and warehouses) to large storage and distribution facilities (e.g. pipeline and marine terminals and wholesale plants), to large integrated facilities (e.g. petroleum refineries and grease production, oil blending, and packaging plants). The specific application of this standard within those various types of operations is itemized in [1.2](#) through [1.8](#).

### 1.2 Petroleum Terminals

Petroleum terminals may include tank farms, loading and unloading areas, pipeline manifolds, storage areas, warehouses, docks, garages, product quality test rooms, and office buildings. Products may be received and distributed by pipeline, marine transport, rail, or truck. Bulk quantities of refined products are stored in aboveground tanks for distribution in smaller quantities to industrial customers, to commercial consumers, and to retail and wholesale marketing facilities. Petroleum terminals may also store petroleum products in consumer packaging, bulk containers, totes, and drums. See USCG 33 *CFR* Parts 154 and 156.

### 1.3 Pipeline Tankage Facilities

Pipeline tankage facilities consist of breakout tanks and tank farms used to receive and transport petroleum (crude oil and refined products) from pipelines and to provide surge relief from pipeline operations (see Office of Pipeline Safety regulation PHMSA 49 *CFR* Part 195).

### 1.4 Refinery Facilities

Provisions for loading and unloading areas, docks, blending and packaging facilities, warehouses, and some refinery tankage facilities are included in this standard. Refinery tankage covered by this standard does not include those aboveground tanks or groups of tanks as defined in [1.9](#) Item c), e.g. process tanks.

Examples of covered refinery tankage include tanks that are used to accomplish the following.

- a) Receive incoming crude oil.
- b) Store intermediate products or components outside of the refinery process units.
- c) Store finished products for shipment by truck, marine transport, rail, or pipeline.